



- 1.1.12 M-500: Relocated location of CU-6 to exterior of building, updated pipe routing for refrigerant. (new location is also depicted in other lower level plans)
- 1.1.13 M-501: Added FFH-ST-BU in STAIR B ST-BU. Added detailing for relocated position of unit heater in EX MECHANICAL 110.
- 1.1.14 M-600: Added detailing for roof drains and ductwork from below.
- 1.1.15 M-700: 1/M-700 Added detailing for traps from JS-2 in mechanical room, detailing for pipe size from drain. Added air terminal for EA duct. 2/M-700 Added detailing to clarify location of work being performed in existing crawlspace. Added Detail 3/M-700 DEMOLITION PART PLAN.
- 1.1.16 M-701: Revised tags on FFH's on details 1/M-701, 2/M-701, and 3/M-701.
- 1.1.17 M-800: Refer to ELECTRIC FORCE FLOW HEATER SCHEDULE: Updated FFH TAG, DOMESTIC HOT WATER TANK SCHEDULE: Revised selection from 208V to 600V, AIR TERMINAL SCHEDULE: Added additional remarks for installation coordination for air terminals.

2.0 CLARIFICATION

- 2.1.1 Additional detail items and scope of work to be added to contract price.

END OF MECHANICAL ADDENDUM

